

## **Z300 PVT specification**

Photovoltaic testing and troubleshooting kit

1500 V / 30A DC - super fast PV tester including fault finding and smart reports functionality.



## 1 Technical data and specifications




Figure 1: In this graph we see the impedance accuracy contour plot for the Z<sub>3</sub>00 PVT

Mechanical	
Enclosure	HPRC 2300
External dimensions	external dimension 335x289x155(mm)
Connectors for DUT	3 x case-side mounted shrouded 4mm ba-
	nana sockets.
	Rated: 1kV CAT III
Environmental	
Storage Temperature	-10° C to 55 °C (limited by battery)
Operating Temperature	o °C to 35 °C (limited by battery)
Operating Altitude	up to 2000 meters
Battery	
Battery model	RCC2054
Technology	Li-Ion, DC 15 V, 3200 mAh, 48.0 Wh
Operating time	8-10 hours
Standby/Sleep time	max. 150 hours in sleep mode
Recharge time	1-2 hours

Measurement feature	Z300 PVT
Frequency coverage	100 Hz to 100 kHz
Frequency accuracy	+/- 2 %
Measurement feature	Z300 PVT
Frequency drift with temperature	>0.1
(° C to 35 ° C)	
Measurement of short circuit current I <sub>SC</sub>	Z300 PVT
DC current range	0-30 A
Measurement of open circuit voltage V <sub>OC</sub>	Z300 PVT
Analysis	Checks for correct polarity and voltage in-
	range.
Range	0-1500V
Measurement of resistance towards	Z300 PVT
ground R <sub>ISO</sub>	
Range	o $\Omega$ - 40 M $\Omega$
Measurement time	about 20 sec.
Conditions	Irradiation $>$ 100 $rac{W}{m^2}$ and
	string V <sub>OC</sub> > 100V
Precision (stable light conditions)	+/- 50 k $\Omega$ +/- 10 $\%$
Analysis	Above 40M $\Omega$ , R <sub>ISO</sub> is returned as
	$R_{\rm ISO} > 40 M \Omega$ .
	Below 100k $\Omega$ , R <sub>ISO</sub> is returned as
	$R_{ISO} < 100 k\Omega$
Detection and localization of ground isola-	Z <sub>3</sub> 00 PVT
tion fault R <sub>ISO</sub>	- MO
Threshold for localization of a ground fault	3 MΩ
Localization precision (stable light condi-	+/- 0.5 PV module
tions)	o.1 PV modules
Localization resolution	
Conditions	Irradiation $>$ 100 $\frac{W}{m^2}$
Analysis	String V <sub>OC</sub> > 100V Fault indicated (with text in user interface)
Analysis	if $R_{ISO}$ <1 M $\Omega$
Measurement of series resistance $R_S$ by	Z300 PVT
the use of impedance spectroscopy i.e. us-	
ing test frequencies	
Conditions	Irradiation $>$ 100 $\frac{W}{m^2}$
Conditions	$m^2$

## 1.1 Shipment information

H Shipment dimensions for standard Z<sub>3</sub>00 kit (may vary if more parts are ordered): (cm:  $35 \times 35 \times 30$ )

Shipment weight: 7 kg

HS code: 9030320000, Oscilloscopes, spectrum analysers and other instruments and apparatus for measuring or checking electrical quantities, excluding meters of heading 9028; instruments and apparatus for measuring or detecting alpha, beta, gamma, X-ray, cosmic or other ionising radiation.